


QDec Measurement Summary

Measurement Information			
Panel:	Helio_AB42	Meas. Date:	07.09.2023 - 23:20:32
Paneltype:	Heliostat	Operator:	DLR
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jÿlich

Result Overview			
Quality:	no specifications	Evaluated Surface: 98.1 %	
Value	Measurement	Specification	Description
SDx	1.54 mrad		Slope deviation in x-direction (rms)
SDy	0.78 mrad		Slope deviation in y-direction (rms)
ICAP_D1	99.44 %		Intercept on aperture



Measurement System Information			
Config File:	130929_Helio	QDec Version:	1.0.5229 (23.02.2022)
Evaluation Date:	18.09.2023 - 11:14:26		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_230907_2\Results\Helio\Helio_AB42\Helio_AB42_Rim0_Result_230918111426.pdf		