

QDec Measurement Summary

Measurement Information




Panel:	Helio_AH35	Meas. Date:	07.04.2016 - 21:36:33
Paneltype:	Heliostat	Operator:	DLR Expert User
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jülich

Result Overview

Quality: no specifications Evaluated Surface: 99.6 %

Value	Measurement	Specification	Description
SDx	1.13 mrad		Slope deviation in x-direction (rms)
SDy	0.99 mrad		Slope deviation in y-direction (rms)
ICAP_D1	99.20 %		Intercept on aperture

Result Graphs



Measurement System Information

Config File:	130929_Helio	QDec Version:	3.1.3680 (14.05.2014)
Evaluation Date:	04.07.2016 - 14:48:06		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_160407\Results\Helio\Helio_AH35\Helio_AH35_Rim0_Result_160704144806.pdf		