


# QDec Measurement Summary

Measurement Information			
<b>Panel:</b>	Helio_AO36	<b>Meas. Date:</b>	09.07.2024 - 00:26:29
<b>Paneltype:</b>	Heliostat	<b>Operator:</b>	DLR
<b>Setup:</b>	MeasPosition	<b>Comment:</b>	
<b>Negl. Rim:</b>	0 mm	<b>System:</b>	QDec_2014-101
<b>Orientation:</b>	Mean Slope to Zero	<b>Location:</b>	Jylich

Result Overview			
<b>Quality:</b>	no specifications	Evaluated Surface: 96.3 %	
Value	Measurement	Specification	Description
SDx	0.82 mrad		Slope deviation in x-direction (rms)
SDy	1.45 mrad		Slope deviation in y-direction (rms)
ICAP_D1	98.80 %		Intercept on aperture



Measurement System Information	
Config File:	130929_Helio <span style="float: right;">QDec Version: 1.0.5229 (23.02.2022)</span>
Evaluation Date:	11.07.2024 - 09:10:07
Last Calibration:	14.08.2014
PDF Filename:	...\MeasData_240709\Results\Helio\Helio_AO36\Helio_AO36_Rim0_Result_240711091007.pdf