

QDec Measurement Summary

Measurement Information


Panel:	Helio_AY36	Meas. Date:	07.09.2023 - 21:38:22
Paneltype:	Heliostat	Operator:	DLR
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jylich

Result Overview

Quality: no specifications Evaluated Surface: 99.6 %

Value	Measurement	Specification	Description
SDx	1.11 mrad		Slope deviation in x-direction (rms)
SDy	1.21 mrad		Slope deviation in y-direction (rms)
ICAP_D1	97.11 %		Intercept on aperture

Result Graphs



Measurement System Information

Config File:	130929_Helio	QDec Version:	1.0.5229 (23.02.2022)
Evaluation Date:	18.09.2023 - 13:36:40		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_230907_2\Results\Helio\Helio_AY36\Helio_AY36_Rim0_Result_230918133640.pdf		