


QDec Measurement Summary

Measurement Information			
Panel:	Helio_AY72	Meas. Date:	06.02.2023 - 18:49:53
Paneltype:	Heliostat	Operator:	CSP-Services
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jülich

Result Overview			
Quality:	no specifications	Evaluated Surface: 98.1 %	
Value	Measurement	Specification	Description
SDx	0.81 mrad		Slope deviation in x-direction (rms)
SDy	1.27 mrad		Slope deviation in y-direction (rms)
ICAP_D1	97.01 %		Intercept on aperture



Measurement System Information			
Config File:	130929_Helio	QDec Version:	1.0.5229 (23.02.2022)
Evaluation Date:	07.02.2023 - 15:25:23		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_230206\Results\Helio\Helio_AY72\Helio_AY72_Rim0_Result_230207152523.pdf		