

QDec Measurement Summary

Measurement Information


Panel:	Helio_BA66	Meas. Date:	06.02.2023 - 18:43:30
Paneltype:	Heliostat	Operator:	CSP-Services
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jülich

Result Overview

Quality: no specifications Evaluated Surface: 89.3 %

Value	Measurement	Specification	Description
SDx	0.77 mrad		Slope deviation in x-direction (rms)
SDy	1.14 mrad		Slope deviation in y-direction (rms)
ICAP_D1	96.46 %		Intercept on aperture

Result Graphs



Measurement System Information

Config File:	130929_Helio	QDec Version:	1.0.5229 (23.02.2022)
Evaluation Date:	07.02.2023 - 14:43:24		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_230206\Results\Helio\Helio_BA66\Helio_BA66_Rim0_Result_230207144324.pdf		