

# QDec Measurement Summary

## Measurement Information


|                     |                    |                    |                       |
|---------------------|--------------------|--------------------|-----------------------|
| <b>Panel:</b>       | Helio_BC62         | <b>Meas. Date:</b> | 06.02.2023 - 18:35:38 |
| <b>Paneltype:</b>   | Heliostat          | <b>Operator:</b>   | CSP-Services          |
| <b>Setup:</b>       | MeasPosition       | <b>Comment:</b>    |                       |
| <b>Negl. Rim:</b>   | 0 mm               | <b>System:</b>     | QDec_2014-101         |
| <b>Orientation:</b> | Mean Slope to Zero | <b>Location:</b>   | Jülich                |

## Result Overview

**Quality:** no specifications Evaluated Surface: 99.2 %

| Value   | Measurement | Specification | Description                          |
|---------|-------------|---------------|--------------------------------------|
| SDx     | 0.73 mrad   |               | Slope deviation in x-direction (rms) |
| SDy     | 1.00 mrad   |               | Slope deviation in y-direction (rms) |
| ICAP_D1 | 97.18 %     |               | Intercept on aperture                |

## Result Graphs



## Measurement System Information

|                          |  |                      |                       |
|--------------------------|--|----------------------|-----------------------|
| <b>Config File:</b>      | 130929_Helio   | <b>QDec Version:</b> | 1.0.5229 (23.02.2022) |
| <b>Evaluation Date:</b>  | 07.02.2023 - 15:26:37  |                      |                       |
| <b>Last Calibration:</b> | 14.08.2014   |                      |                       |
| <b>PDF Filename:</b>     | ...\MeasData_230206\Results\Helio\Helio_BC62\Helio_BC62_Rim0_Result_230207152637.pdf |                      |                       |