

QDec Measurement Summary

Measurement Information





Panel:	Helio_BE37	Meas. Date:	10.05.2016 - 23:19:57
Paneltype:	Heliostat	Operator:	DLR Expert User
Setup:	MeasPosition	Comment:	
Negl. Rim:	0 mm	System:	QDec_2014-101
Orientation:	Mean Slope to Zero	Location:	Jülich

Result Overview

Quality: no specifications Evaluated Surface: 92.0 %

Value	Measurement	Specification	Description
SDx	0.88 mrad		Slope deviation in x-direction (rms)
SDy	0.76 mrad		Slope deviation in y-direction (rms)
ICAP_D1	96.93 %		Intercept on aperture

Result Graphs



Measurement System Information

Config File:	130929_Helio	QDec Version:	3.1.3680 (14.05.2014)
Evaluation Date:	12.05.2016 - 11:30:27		
Last Calibration:	14.08.2014		
PDF Filename:	...\MeasData_160510\Results\Helio\Helio_BE37\Helio_BE37_Rim0_Result_160512113027.pdf		