

# QDec Measurement Summary

## Measurement Information





<b>Panel:</b>	Helio_BJ32	<b>Meas. Date:</b>	14.11.2019 - 19:38:48
<b>Paneltype:</b>	Heliostat	<b>Operator:</b>	DLR
<b>Setup:</b>	MeasPosition	<b>Comment:</b>	
<b>Negl. Rim:</b>	0 mm	<b>System:</b>	QDec_2014-101
<b>Orientation:</b>	Mean Slope to Zero	<b>Location:</b>	Jülich

## Result Overview

**Quality:** no specifications      Evaluated Surface: 75.5 %

Value	Measurement	Specification	Description
SDx	0.63 mrad		Slope deviation in x-direction (rms)
SDy	0.71 mrad		Slope deviation in y-direction (rms)
ICAP_D1	96.51 %		Intercept on aperture

## Result Graphs



## Measurement System Information

<b>Config File:</b>	130929_Helio	<b>QDec Version:</b>	3.1.4859 (31.10.2018)
<b>Evaluation Date:</b>	15.11.2019 - 09:59:56		
<b>Last Calibration:</b>	14.08.2014		
<b>PDF Filename:</b>	T:\191114_SKT_\Results\Helio\Helio_BJ32\Helio_BJ32_Rim0_Result_191115095956.pdf		